

Acton Board of Health

Room 9, Acton Town Hall  
Acton, MA 01720  
April 10, 2017

Members Present: Joanne Bissetta –Chairman, Dr. William Taylor, William McInnis and Mark Conoby

Staff Present: Sheryl Ball- Health Director  
Weiyuan Sun-Administration

Other Present: Molly Obendorf, Rekha Singh and Peggy Mikkola

The meeting was called to order at 7:37 p.m.

**Minutes**

On a motion made by Mr. Conoby, seconded by Dr. Taylor, the Board unanimously voted to approve the Board of Health minutes dated March 13, 2017 as amended.

**Variance- 30 Mohawk Drive**

The Health Department received a request from the owners of the property located at 30 Mohawk Drive for a variance from 310 CMR 15.211(1), and 310 CMR 15.227 (5). On a motion made by Mr. Conoby, seconded by Mr. McInnis, the Board unanimously voted to approve the variance with the following conditions:


- 1) The septic tank shall be pumped a minimum of once every two years.
- 2) The septic tank shall be proven water tight and sealed with either hydraulic cement or watertight sleeves.
- 3) The leach field shall have a 40 mil poly barrier installed on the outer perimeter in between the field and cellar wall.
- 4) System vent shall be no closer than 10 feet to the property line.
- 5) The system shall be constructed in accordance with the above listed conditions and a plan stamped by a representative of Stamski and McNary.

**Adjournment**

On a motion made by Mr. McInnis, seconded by Dr. Taylor, the Board voted to adjourn the meeting at 7:51 P.M.

Respectfully Submitted,

  
Weiyuan Sun, Administrator  
Acton Board of Health

  
Joanne Bissetta, Chairman  
Acton Board of Health